

2025 Annual Drinking Water Quality Report

Town of Silverhill

MAYOR AND COUNCIL

Jared Lyles, Mayor
Bert Jones

Steve Brooks
Tonie Norden

Wayne Gruenloh
Gerald Ardoin

EMPLOYEES

Scottie Smith, Water Superintendent

Amy Macon, Utility Clerk

Nicole Haigler, Town Clerk

BOARD MEETING TIME

The Town of Silverhill Town Council meetings are held the 1st and 3rd Monday of each month at 6 P.M. at Silverhill Town Hall located at 15965 Silverhill Ave.

The Town of Silverhill is pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

We have completed our Source Water Assessment, and a Well Head Protection Plan available for review at Town Hall. We are continually working on it to ensure it provides more information such as potential sources of contamination. We are pleased to report that our drinking water is safe and meets federal and state requirements. If you have any questions about this report or concerning your water quality, please contact Scottie Smith, 251-945-5198 or attend any of our regularly scheduled council meetings.

Our water sources are groundwater. Our wells draw water from the Miocene-Pliocene Aquifer. Well #1 is located at Silverhill ballpark and Well #2 is located behind the Town Hall.

The Town of Silverhill adds chlorine to the water to kill bacteria. Lime is added to produce a desirable water quality by raising the pH level to reduce corrosion and acidic conditions.

Silverhill routinely monitors for constituents in your drinking water according to federal and state laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2025. All drinking water, including bottled water, may be reasonably expected to contain at least small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

PLAIN LANGUAGE DEFINITIONS

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Not Required (NR) - Laboratory analysis not required due to waiver granted by the Environmental Protection Agency for the State of Alabama

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity more than 5 NTU is just noticeable to the average person.

Variances & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - (mandatory language) A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Threshold Odor Number (T.O.N.) The greatest dilution of a sample with odor-free water that still yields a just-detectable odor.

Maximum Contaminant Level - (mandatory language) The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - (mandatory language) The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level Goal or MRDLG - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level or MRDL - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Table of Primary Contaminants

At high levels some primary contaminants are known to pose health risk to humans.
This table provides a quick glance of any primary contaminant detections.

CONTAMINANT	MCL	AMOUNT DETECTED	CONTAMINANT	MCL	AMOUNT DETECTED
Bacteriological			Endothall	100	<9.0
Total Coliform Bacteria	< 5%	0	Endrin	2	0.6
Turbidity	TT	0.02	Epichlorohydrin	TT	ND
Radiological			Glyphosate	700	<6.0
Beta/photon emitters (mrem/yr)	4	ND	Heptachlor	400	0.04
Alpha emitters (pci/l)	15	NR	Heptachlor epoxide	200	0.02
Combined radium (pci/l)	5	ND	Hexachlorobenzene	1	0.1
Inorganic			Hexachloropentadiene	1	0.1
Antimony (ppb)	6	ND	Lindane	200	ND
Arsenic (ppb)	50	ND	Methoxychlor	40	0.1
Asbestos (MFL)	7	NR	Oxamyl [Vydate]	200	ND
Barium (ppm)	2	0.020	PCBs	500	ND
Beryllium (ppb)	4	.002	Pentachlorophenol	1	0.04
Cadmium (ppb)	5	.005	Picloram	500	ND
Chromium (ppb)	100	ND	Simazine	4	ND
Copper (ppm)	AL=15	0.0026	Toxaphene	3	1.0
Cyanide (ppb)	200	.05	Benzene	5	0.5
Fluoride (ppm)	4	.02	Carbon Tetrachloride	5	0.5
Lead (ppb)	AL=15	0.0011	Chlorobenzene	100	0.5
Mercury (ppb)	2	ND	Dibromochloropropane	200	2.0
Nitrate (ppm)	10	0.28	O-Dichlorobenzene	600	ND
Nitrite (ppm)	1	.01	p-Dichlorobenzene	75	ND
Selenium	50	ND	1,2-Dichloroethane	5	0.5
Thallium	2	ND	1,1-Dichloroethylene	7	0.5
Organic Chemicals			Cis-1,2-Dichloroethylene	70	0.5
2,4-D	70	0.1	trans-1,2-Dichloroethylene	100	0.5
2,4,5-TP (Silvex)	50	0.1	Dichloromethane	5	0.5
Acrylamide	TT	ND	1,2-Dichloropropane	5	0.5
Alachlor	2	ND	Ethylbenzene	700	0.5
Atrazine	3	ND	Ethylene dibromide	50	ND
Benzo(a)pyrene[PHAs]	200	0.02	Styrene	100	0.5
Carbofuran	40	ND	Tetrachloroethylene	5	0.5
Chlordane	2	0.1	1,2,4-Trichlorobenzene	70	0.5
Dalapon	200	1.0	1,1,1-Trichloroethane	200	0.5
Di-(2-ethylhexyl)adipate	400	0.6	1,1,2-Trichloroethane	5	0.5
Di(2-ethylhexyl)phthlates	6	0.6	Trichloroethylene	5	0.5
Dinoseb	7	0.1	TTHM	80	NR
Diquat	20	<0.4	Toluene	1	0.5
Dioxin [2,3,7,8-TCDD]	30	ND	Vinyl Chloride	2	0.5
HAA5's	60	NR	Xylenes	10	0.5

Table of Secondary Contaminants

CONTAMINANT	MCL	UNIT	DETECTED	CONTAMINANT	MCL	DETECTED	UNIT
Aluminum	0.2	Mg/l	0.050	Manganese	0.05	0.001	mg/l
Chloride	250	mg/l	6.5	Odor	3	1.	threshold odor #
Color	15	PCU	5	Sulfate	250	55.9	mg/l
Copper	1	mg/l	0.0026	Total Dissolved Solids	500	52	mg/l
Foaming Agents	0.5	mg/l	0.02	Zinc	5	0.002	ND
Iron	0.3	mg/l	ND	Silver	0.1	.004	ND

Table of Unregulated Contaminants

CONTAMINANT	Average	Range	CONTAMINANT	Average	Range
1,1 - Dichloropropene	<0.5	0.000 - 0.000	Chloroform	0.014	0.000 - 0.0000
1,1,1,2-Tetrachloroethane	<0.5	0.000 - 0.000	Chloromethane	<0.5	0.000 - 0.000
Trans-1,3-Dichloropropene	<0.5	0.000 - 0.000	Monochlorobenzene	ND	0.000 - 0.000
o-Xylene	ND	0.000 - 0.000	M,p-Xylene	ND	0.000 - 0.000
Methyl-t-Butyl Ether	<0.5	0.000 - 0.000	Chlorodibromomethane	ND	0.000 - 0.000
1,1,2,2-Tetrachloroethane	<0.5	0.000 - 0.000	Dibromochloromethane	0.003	0.000 - 0.000
1,1-Dichloroethane	<0.5	0.000 - 0.000	Dibromomethane	<0.5	0.000 - 0.000
1,2,3 - Trichlorobenzene	<0.5	0.000 - 0.000	Dicamba	ND	0.000 - 0.000
1,2,3 - Trichloropropane	<0.5	0.000 - 0.000	Dichlorodifluoromethane	ND	0.000 - 0.000
1,2,4 - Trimethylbenzene	<0.5	0.000 - 0.000	Dieldrin	<0.1	0.000 - 0.000
1,3 - Dichloropropane	<0.5	0.000 - 0.000	Hexachlorobutadiene	<0.5	0.000 - 0.000
1,3 - Dichloropropene	ND	0.000 - 0.000	Isoprpylbenzene	<0.5	0.000 - 0.000
1,3,5 - Trimethylbenzene	<0.5	0.000 - 0.000	M-Dichlorobenzene	ND	0.000 - 0.000
2,2 - Dichloropropane	<0.5	0.000 - 0.000	Methomyl	ND	0.000 - 0.000
3-Hydroxycarbofuran	ND	0.000 - 0.000	MTBE	ND	0.000 - 0.000
Aldicarb	<0.5	0.000 - 0.000	Metolachlor	<0.1	0.000 - 0.000
Aldicarb Sulfone	<0.7	0.000 - 0.000	Metribuzin	<0.1	0.000 - 0.000
Aldicarb Sulfoxide	<0.5	0.000 - 0.000	N - Butylbenzene	<0.5	0.000 - 0.000
Aldrin	<0.1	0.000 - 0.000	Naphthalene	<0.5	0.000 - 0.000
Bromobenzene	<0.5	0.000 - 0.000	N-Propylbenzene	<0.5	0.000 - 0.000
Bromochloromethane	<0.5	0.000 - 0.000	O-Chlorotoluene	ND	0.000 - 0.000
Bromodichloromethane	<0.5	0.000 - 0.000	P-Chlorotoluene	ND	0.000 - 0.000
Bromoform	<0.5	0.000 - 0.000	P-Isopropyltoluene	ND	0.000 - 0.000
Bromomethane	<0.5	0.000 - 0.000	Propachlor	<0.1	0.000 - 0.000
Butachlor	ND	0.000 - 0.000	Sec - Butylbenzene	<0.5	0.000 - 0.000
Carbaryl	<0.5	0.000 - 0.000	Tert - Butylbenzene	<0.5	0.000 - 0.000
Chloroethane	ND	0.000 - 0.000	Trichlorfluoromethane	<0.5	0.000 - 0.000
Flourotrichloromethane	ND	0.000 - 0.000			

Table of Detected Contaminants

Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
3. Turbidity	NO	0.20	ntu	n/a	TT	Soil runoff
10. Barium	NO	0.020	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

14. Copper	NO	0.035	Ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Chromium, Total	NO	0.014	Mg/l	100ppg	100ppg	Discharge from steel and pulp mills; Erosion from natural deposits
5. Alpha emitters	NO	0.6+/-0.3	pCi/l	0	15	Erosion of natural deposits
16. Fluoride	NO	ND	Ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
19. Nitrate (as Nitrogen)	NO	1.2	Ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
73. TTHM [Total trihalomethanes]	NO	0.015	ppb	0	80	By-product of drinking water chlorination
HAA5's	NO	0.0023	ppb	0	60	By-product of drinking water chlorination

Table of Detected Special Contaminants

	Amount Detected		Amount Detected		Amount Detected
Calcium	5.87	PH	8.46	Langelier Index	-.751
Magnesium	1.04	Carbon Dioxide	ND	Conductivity	57.0
Sodium	3.50	Temperature	23.	Calcium Hardness	NR
Alkalinity	14	Hardness CaCo3	18.9		

- Lead and Copper results, based on the 90th percentile, are from the 2024 test period.
- A 1.4 ppm to 1.7 ppm Chlorine level was maintained in 2025.

GENERAL INFORMATION

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

All drinking water, including bottled water, may be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. **More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).**

Some people may be more vulnerable to contaminants in drinking water than the general population. People who are immuno-compromised, such as cancer patients undergoing chemotherapy, organ transplant recipients, HIV/AIDS positive or individuals with other immune system disorders, some elderly, and infants, can be particularly at risk from infections. Those at risk should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Based on a study conducted by the ADEM with the approval of the EPA, a statewide waiver for the monitoring of Asbestos and Dioxin was issued. Thus, monitoring for these contaminants was not required.

On June 11, 2025 the Silverhill Water System had a bad B.T. sample, one sample tested good and one sample tested bad. On June 13, 2025 another sample was taken at the same location along with a sample up stream and one down stream and they all were good. The bad sample could have been due to a contaminated collection container or accidental contamination by the collector.

We at the Town of Silverhill work around the clock to provide top quality water to every tap. We ask that all of our customers help us protect our water sources, which are the heart of our community, our way of life, and our children's future.